

561568

County Wright  
Quad  
Quad ID

MINNESOTA DEPARTMENT OF HEALTH  
WELL AND BORING REPORT  
Minnesota Statutes Chapter 1031

Entry Date 05/09/1997  
Update Date 02/14/2014  
Received Date

<b>Well Name</b> SOUTHBROOK	<b>Township</b> 121	<b>Range</b> 28	<b>Dir</b> W	<b>Section</b> 25	<b>Subsection</b> CDA	<b>Well Depth</b> 50 ft.	<b>Depth Completed</b> 50 ft.	<b>Date Well Completed</b> 07/15/1996
<b>Elevation</b>						<b>Drill Method</b> Non-specified Rotary	<b>Drill Fluid</b> Bentonite	
<b>Address</b>						<b>Use</b> domestic	<b>Status</b> Active	
Well 7250 MORRISON AV MN						<b>Well Hydrofractured?</b> Yes <input type="checkbox"/> No <input type="checkbox"/> <b>From</b> <b>To</b>		
Contact 125 PARK ST E ANNANDALE MN 55302						<b>Casing Type</b> Single casing <b>Joint</b>		
<b>Stratigraphy Information</b>						<b>Drive Shoe?</b> Yes <input type="checkbox"/> No <input type="checkbox"/> <b>Above/Below</b>		
<b>Geological Material</b>		<b>From</b>	<b>To (ft.)</b>	<b>Color</b>	<b>Hardness</b>	<b>Casing Diameter</b> <b>Weight</b> <b>Hole Diameter</b>		
CLAY		0	6	BROWN	MEDIUM	12 in. To 30 ft. lbs./ft. 18 in. To 50 ft.		
GRAVEL		6	14	BROWN	SOFT			
CLAY ROCKY		14	17	BROWN	MEDIUM			
SAND 15- 30		17	38	LT. BRN	SOFT			
GRAVEL		38	50	ORN/BRN	MEDIUM			
						<b>Open Hole</b> From ft. To ft.		
						<b>Screen?</b> <input checked="" type="checkbox"/> <b>Type</b> stainless <b>Make</b> JOHNSON		
						Diameter Slot/Gauze Length Set		
						12 in. 35 20 ft. 30 ft. 50 ft.		
						<b>Static Water Level</b>		
						14 ft. land surface Measure 04/06/1996		
						<b>Pumping Level (below land surface)</b>		
						22 ft. 7 hrs. Pumping at 300 g.p.m.		
						<b>Wellhead Completion</b>		
						Pitless adapter manufacturer Model		
						<input type="checkbox"/> Casing Protection <input type="checkbox"/> 12 in. above grade		
						<input type="checkbox"/> At-grade (Environmental Wells and Borings ONLY)		
						<b>Grouting Information</b> Well Grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Specified		
						Material Amount From To		
						bentonite 6 Sacks 0 ft. 30 ft.		
						<b>Nearest Known Source of Contamination</b>		
						200 feet East Direction Septic tank/drain field Type		
						Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
						<b>Pump</b> <input type="checkbox"/> Not Installed Date Installed 07/15/1996		
						Manufacturer's name WESTERN		
						Model Number 10JCZ7 HP 30 Volt 460		
						Length of drop pipe ft Capacity 250 g.p. Typ Submersible		
						<b>Abandoned</b>		
						Does property have any not in use and not sealed well(s)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
						<b>Variance</b>		
						Was a variance granted from the MDH for this well? <input type="checkbox"/> Yes <input type="checkbox"/> No		
						<b>Miscellaneous</b>		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - Mad83, Zone 15, Meters X Y		
						Unique Number Verification Inpute Date		
						<b>Angled Drill Hole</b>		
						<b>Well Contractor</b>		
						Ingleside Engr. 27355 DHEN, D.		
						Licensee Business Lic. or Reg. No. Name of Driller		