


DEC 13 2000



## NOTES:

1. CUSTOMER TO VERIFY OVERALL DIMENSIONS TO INSURE CLEARANCE WITH EXISTING STRUCTURE.
2. ALL ERECTION, WIRING, DUCTING, FOUNDATION AND CALLOUTS INDICATED WITH AN (\*) ARE BY CUSTOMER, "BY CUSTOMER" INDICATES A SUPPLIER OTHER THAN CLEMCO INDUSTRIES.
3. THIS DRAWING IS FOR CUSTOMER APPROVAL ONLY, UNLESS OTHERWISE NOTED.
4. DO NOT SCALE DRAWING.
5. FOR SUGGESTED DUCTING DETAILS, SEE DWG. DFSK-50016

## SPECIFICATIONS:

AIR VOLUME - 5400 CFM  
VENTILATION RATE - 75 FPM  
CLOTH AREA - 2832 SQ. FT.  
AIR/CLOTH RATIO - 2:1  
STATIC PRESSURE - 6 IN. W.G.  
ELECTRICAL REQUIREMENTS - 480V-3PH-60 HZ

APPROVED ~ WITHOUT EXCEPTIONS

APPROVED ~ EXCEPT AS NOTED

ELECTRICAL POWER FOR MOTORS  
IS \_\_\_\_\_ VOLTS \_\_\_\_\_ PH. \_\_\_\_\_ HZ.SINGLE PHASE 110/120 VOLT POWER  
FOR LIGHTS 1S/1S NOT AVAILABLE  
( \_\_\_\_\_ AMPS REQUIRED)

SIGNED

DATE

NOV '00 6676-00 BF GOODRICH AEROSPACE  
DATE JOB NO. PREPARED FOR

CLEMCO INDUSTRIES

SCALE GENERAL ARRANGEMENT FOR  
8' L x 3' W SCREW CONVEYOR, RPH-12L  
DUST COLLECTOR

| DATE     | BY | DATE     | BY | DATE     | BY | DRAWING NO | REV  |
|----------|----|----------|----|----------|----|------------|------|
| 11-21-00 | DW | 11-21-00 | GS | 11-21-00 | GS | B6676G001  | 0    |
|          |    |          |    |          |    | SHEET 1    | OF 2 |

NOTE: This drawing is the confidential property of CLEMCO INDUSTRIES. It is not to be copied or duplicated in any manner, and shall not be submitted to outside parties without our written consent.